

25X1C4e

STANDARD OPERATING PROCEDURE  
NUMBER 45-3144-7

3 March 1965

TESTING OF DEMINERALIZED WATER

1. PURPOSE: To establish standard procedures for quality control and testing of demineralized water.
2. SCOPE: This procedure applies to all POL personnel.
3. RESPONSIBILITIES: The Petroleum Officer will be responsible for Quality Control and Testing of all demineralized water.
4. PROCEDURES:
  - a. All demineralized water will be tested, utilizing the Conductivity Bridge, Model RC 16B2, on a weekly basis for parts per million.
  - b. Testing will be conducted by demineralized water truck number each Monday and results recorded. (See sample log attached)
  - c. In addition to the weekly testing, demineralized water will be tested and results recorded prior to issue to any aircraft.
  - d. Testing and recording results of demineralized water will be the responsibility of the NCOIC, Storage Section.
  - e. Test results exceeding the allowable limits (10 parts per million) will be reported to the Petroleum Officer.

25X1A9a

25X1A9a

*[Signature]*  
Colonel, USAF  
Commander

1 Atch  
Report of Water Analysis

**SECRET**

Approved For Release 2001/08/27 : CIA-RDP33-02415A000600070037-7

[illegible]

# SHORT

Atch 1 to SOP 45-3144-7